



- KEYED NOTES**
- 1 EXISTING UNDERGROUND SECONDARY FEEDER FROM UTILITY TRANSFORMER. CUT AND REMOVE PORTION OF PIPE RUNNING UP WALL. MAINTAIN EXISTING FEEDER CONDUCTORS.
 - 2 EXISTING UNDERGROUND 3/4" CONDUIT. REMOVE FEEDER CONDUCTORS AND SAVE CONDUIT FOR NEW FEEDER.
 - 3 REMOVE EXISTING PANELS. SEE NEW ELECTRICAL RISER DIAGRAM AND PANEL SCHEDULES FOR ADDITIONAL INFORMATION.
 - 4 EXISTING 3" UNDERGROUND CONDUIT. REMOVE EXISTING FEEDER. MAINTAIN EXISTING RACEWAY FOR RE-USE.
 - 5 REMOVE EXISTING SERVICE DISCONNECT, WIRING, AND WIREWAY.
 - 6 REMOVE EXISTING SWITCHBOARD. MAINTAIN EXISTING FEEDERS TO BRANCH CIRCUIT THAT REQUIRE RECONNECTION.

REVISIONS		NO.	DATE	COMMENTS
NO.	DATE			

RENOVATION/RESTORATION PROJECT

MARINER BEACH CLUB
 4220 GULF BOULEVARD
 ST. PETERSBURG BEACH, FLORIDA 33706

billerreinhardt
 STRUCTURAL GROUP, INC.
 4014 gulf highway suite 248, tampa, florida 33618
 telephone : 813.908.7203 fax : 813.908.7303
 email : info@billerreinhardt.com
 State of Florida Certificate of Authorization No. 9149

USE THE SET OF THE CONTRACT DOCUMENTS FOR THE PLANS AND SPECIFICATIONS COMPLETE WITH THE APPLICABLE NATIONAL BUILDING CODES

ELECTRICAL SITE PLAN

DATE: 02-23-09 DRAWN BY: CSR
 JOB NO: 08-132 DESIGN BY: OFB

SITE PLAN - DEMOLITION PLAN
 SCALE: 3/32" = 1'-0"

ENGINEERING MATRIX, INC.
 CONSULTING ENGINEERS
 2860 SCHERER DRIVE, SUITE 640
 ST. PETERSBURG, FLORIDA 33716
 (727) 573-6656 FAX: (727) 573-3902 EMAIL: email@engmtx.com
 CERT. OF AUTHORIZATION NO. 4288 EMI JOB NO. 08-1320
 © 2009 Engineering Matrix, Inc.

SHEET NO.
E2.0